CHULA VISTA FIRE DEPARTMENT

FIRE PREVENTION DIVISION

PREMISES IDENTIFICATION

Building Address Numbers:

Address must be plainly visible and legible from the street or main access to the building. Numbers shall contrast with their background and comply with the following:

Distance from Building to Face of Curb	Minimum Height	Minimum Stroke
0 - 50 feet	6 inches	1 inch
51 - 150 feet	10 inches	1 ½ inches
> 151 feet	16 inches	2 inches

Suite Numbers:

Numbers shall contrast with their background and comply with the following:

Minimum Height	Minimum Stroke
4 inches	¾ inch

ADDITIONAL SPECIFICATIONS:

- This policy also applies to monument signs.
- Buildings may be required to have the address posted in multiple locations.

